



दिल्ली मेट्रो रेल कॉर्पोरेशन लि०
DELHI METRO RAIL CORPORATION LTD.

(A JOINT VENTURE OF GOVERNMENT OF INDIA AND GOVT. OF DELHI)

Project Office : Chief Electrical Engineer/Elect/PS-1,
9/11, Mall Road, Delhi-110054

01 23813073
Fax 23814339

No. DMRC/CEE-1/PS-1/CE-05 LOT-2/VEN-APPL/252

Dated: 25.06.2015

M/s ETA Engineering Pvt. Ltd.
ETA HOUSE: B-13, Sector-63,
NOIDA-201307, U.P., India.
Tel: 0120-4007800 Fax: 0120-4007899


Kind Attn: Shri Saurabh Chauhan, General Manager.

Sub: Contract: CE-5 LOT-2: Approval of Vendor/ Technical detail for air washer and scrubber make:
M/s Dynamic Engineering.

- Ref:**
1. M/s ETA letter No. ETA/DMRC/PIII/DEPOTS/L-2/SC/176 dated 16.07.2014.
 2. DMRC letter No. DMRC/CEE/PS-1/CE 5 LOT 2/VEN APPL/252 dated 14.08.2015.
 3. M/s ETA letter No. ETA/DMRC/PIII/DEPOTS/SC/238 dated 20.09.2014.
 4. M/s ETA letter No. ETA/DMRC/PIII/DEPOTS/SC/278 dated 11.11.2014.
 5. DMRC letter No. DMRC/CEE/PS-1/CE 5 LOT 2/VEN APPL/252 dated 09.12.2014.
 6. M/s ETA letter No. ETA/DMRC/PIII/DEPOTS/SC/394 dated 24.03.2015.
 7. DMRC letter No. DMRC/CEE/PS-1/CE 5 LOT 2/VEN APPL/252 dated 26.03.2015.
 8. M/s ETA letter no. ETA/DMRC/PIII/DEPOTS/SC/468 dated 04.06.2015.
 9. DMRC letter No. DMRC/CEE/PS-1/CE 5 LOT 2/VEN APPL/252 dated 04.06.2015.

Vide above referred letter dated 04.06.2015 M/s ETA submitted the Vendor/ Technical detail for air washer and scrubber make: M/s Dynamic Engineering and requested for necessary approval. The vendor/ technical submittal has been examined and DMRC conveys "No Objection" to approval of the same with subject to followings:-

- a. Financial implication will be applicable against non compliance of required efficiency as per contract agreement PS clause no. H-02, C, 1.2 i.e. 80 %.


(Rajesh Chaturvedi)
Chief Electrical Engineer/PS-1